

Ftm50 Agg2a2a32aa

A practical guide to ftm50 agg2a2a32aa, covering the reader intent, the relationship to ftm50 agg2a2a32aa, key evaluation criteria, common risks, and the information the intended project audience should confirm before taking the next step.



[levelmeter.org](https://www.level-meters.com/)

Main topic: Main Page

<https://www.level-meters.com/>

In the landscape of industrial automation and bulk solids management, precision in point level detection is critical for preventing silo overfills, protecting downstream equipment, and ensuring process continuity. The configuration string `ftm50 agg2a2a32aa` represents a specific technical build for a vibronic level switch designed primarily for fine-grained solids and powders. Understanding the nuances of this specific model code is essential for engineers and procurement specialists who require a reliable interface between physical material storage and electronic control systems.

As a professional manufacturer of industrial level measurement instruments, Welk provides comprehensive insights into the engineering principles that govern these devices. This guide explores the measurement mechanics, technical specifications, and application considerations for the `ftm50 agg2a2a32aa`, while offering a broader perspective on level measurement solutions available on our Main Page.

| Measurement Principle: The Vibronic Effect in Solids

The `ftm50 agg2a2a32aa` operates on the vibronic (vibrating fork) principle. Unlike liquid level switches that might use float or hydrostatic methods, solids require a technology that can withstand mechanical abrasion and varying bulk densities.

| Frequency Shift Mechanics

The sensor consists of a symmetric vibrating fork. An internal piezo-electric crystal excites the fork to its resonant frequency, typically in the range of 80 Hz to 140 Hz for solids. When the fork is free of material, it vibrates at its maximum amplitude and natural frequency. As the medium (such as flour, plastic granules, or cement) covers the fork, the frequency shifts and the amplitude is dampened due to the mechanical resistance of the solids.

| Signal Processing

The internal electronics of the ftm50 agg2a2a32aa detect this frequency change. Once the shift crosses a calibrated threshold, the device switches its output state. This technology is highly robust because it is generally unaffected by the dielectric constant of the material, moisture content, or external vibrations from the silo structure. This makes it a preferred choice over capacitive sensors in applications where material properties are inconsistent.

| Decoding the Ftm50 Agg2a2a32aa Configuration

To ensure the instrument meets the demands of a specific process, it is vital to decode the alphanumeric string. Each segment of the code ftm50 agg2a2a32aa corresponds to a specific hardware or software feature. While configurations can vary slightly by regional standards, the following breakdown represents the standard engineering profile for this build:

Code Segment	Feature Category	Specification Detail
FTM50	Product Series	Vibronic point level switch for fine-grained solids.
A	Approval	Non-hazardous area (Standard/General Purpose).
GG	Process Connection	Thread ISO228 G1-1/2, 316L stainless steel.
2	Material/Surface	316L; standard surface finish for industrial use.
A	Sensor Length	Compact version; standard fork length (approx. 145mm).
2	Electronic Insert	3-wire PNP (10-55V DC) for PLC integration.
A	Housing	F17 Aluminum housing, IP66/67 protection.
3	Cable Entry	G1/2 thread for conduit or cable glands.
2	Additional Option	Basic version without specialized coatings or high-temp extensions.
AA	Software/Version	Standard factory calibration and software release.

This specific configuration is optimized for standard industrial environments where explosive atmospheres are not present, and the process connection requires a standard 1.5-inch thread. For users requiring different process connections or hazardous area certifications, alternative configurations can be explored through the technical documentation on our Main Page.

| Key Evaluation Criteria for Solids Level Switches

When evaluating the ftm50 agg2a2a32aa for a project, engineers must look beyond the part number and consider the physical properties of the medium and the vessel environment.

| Bulk Density Requirements

Vibronic switches have a minimum bulk density requirement to ensure the frequency shift is detectable. The ftm50 agg2a2a32aa is typically rated for materials with a density starting from 10 g/l (grams per liter). If the material is extremely light, such as aerated silica or very fine fluff, the dampening effect may be insufficient. Conversely, for very heavy ores, the mechanical stress on the fork must be calculated.

| Grain Size and Flowability

This device is designed for fine-grained solids, generally with a maximum grain size of 10 mm. In applications involving large rocks or heavy aggregate, there is a risk of material wedging between the fork tines, which can cause a "false covered" signal. For larger aggregates, a rotary paddle switch or a heavy-duty vibrating rod may be more appropriate.

| Temperature and Pressure Limits

The standard ftm50 agg2a2a32aa is typically rated for process temperatures ranging from -50°C to +150°C and pressures up to 25 bar (2.5 MPa). Exceeding these limits can lead to piezo-electric failure or seal degradation. In high-pressure steam environments or cryogenic storage, specialized transmitters are required.

| Practical Selection Table: Technology Comparison

Choosing the right level switch involves comparing vibronic technology against other common methods used in industrial automation.

Feature	Vibronic (FTM50)	Rotary Paddle	Capacitive Switch	Ultrasonic (Point)
Media Type	Fine solids/powders	Granules/Coarse	Liquids/Solids	Liquids
Moving Parts	No (Micro-vibration)	Yes (Motorized)	No	No
Maintenance	Low	Moderate	Low	Moderate
Build-up Sensitivity	Low	High	High	Moderate
Primary Risk	Fork wedging	Motor burnout	Coating/Dielectric change	Acoustic noise
Best Use Case	Silo high/low alarm	Heavy aggregate	Constant dielectric	Non-contact liquid

Installation Considerations and Best Practices

Proper installation of the ftm50 agg2a2a32aa is as important as the device selection itself. Incorrect placement can lead to premature wear or inaccurate readings.

- 1. Orientation and Positioning:** For high-level alarms, the device should be installed such that the fork tines are vertical (if side-mounted) or pointing downwards (if top-mounted). This prevents material from resting on the flat surfaces of the fork, which could cause a false alarm.
- 2. Avoiding the Fill Stream:** The sensor must never be placed directly in the path of the incoming material flow. The kinetic energy of falling solids can damage the tines or cause excessive wear. If the mounting point is near the inlet, a protective baffle plate should be installed above the sensor.
- 3. Cable Entry Direction:** When using the F17 aluminum housing, always ensure the cable entries point downwards. This creates a "drip loop" that prevents moisture from entering the housing via the cable, maintaining the IP67 integrity.

4. **Nozzle Length:** If the sensor is mounted on a nozzle, the fork must extend fully into the vessel. If the tines are recessed within a narrow nozzle, material may bridge across the opening, preventing the fork from vibrating freely or trapping material inside the nozzle.

| Limitations and Common Risks

While the ftm50 agg2a2a32aa is a highly versatile instrument, it is not a "one-size-fits-all" solution. Engineers should be aware of the following limitations:

Material Bridging: In very sticky or damp powders, material can build up between the tines. While the vibronic principle is somewhat self-cleaning due to the vibration, extreme buildup will eventually dampen the signal permanently.

Mechanical Load: In tall silos, the weight of the settling solids (lateral load) can be immense. If the sensor is mounted too low in a very high silo without protection, the tines may bend or break.

Abrasive Wear: Although 316L stainless steel is durable, highly abrasive materials like glass cullet or certain ores will eventually erode the fork. In these cases, coatings or thicker-profile sensors are necessary.

| Frequently Asked Questions (FAQ)

Q: Can the ftm50 agg2a2a32aa be used for liquid applications?

A: While technically a vibrating fork, this specific model is tuned for the frequency ranges and densities of solids. For liquid applications, a different tuning fork series designed for liquid densities (typically 0.5 to 2.5 g/cm³) should be used to ensure accuracy.

Q: What is the significance of the 3-wire PNP electronic insert?

A: The 3-wire PNP output (24V DC) is a standard industrial signal that allows the switch to interface directly with a PLC (Programmable Logic Controller) input card. It provides a discrete "on/off" signal based on the level state.

Q: How do I test the device without filling the silo?

A: Most configurations include a test magnet or a local button on the electronic insert that allows for a functional check of the relay/output without needing to submerge the fork in material.

| Conclusion

The ftm50 agg2a2a32aa is a robust, engineering-grade solution for point level detection in fine solids. By leveraging the vibronic principle, it offers a maintenance-free alternative to mechanical switches, provided that the installation and process conditions align with its technical limits. For projects requiring continuous level measurement, such as radar or ultrasonic transmitters, or for alternative switch technologies, we invite you to review the full range of industrial instruments on our Main Page. Selecting the right tool for the application is the first step toward achieving operational excellence and safety in industrial automation.