

Vdi2770

A practical guide to vdi2770, covering the reader intent, the relationship to vdi2770, key evaluation criteria, common risks, and the information the intended project audience should confirm before taking the next step.



[levelmeter.org](https://www.level-meters.com/)

Main topic: Main Page

<https://www.level-meters.com/>

In the modern industrial landscape, the transition from paper-based documentation to standardized digital formats is no longer a luxury but a requirement for operational efficiency. VDI 2770 is a pivotal guideline developed by the Association of German Engineers (Verein Deutscher Ingenieure) that defines the minimum requirements for digital manufacturer information in the process industry. For engineers and procurement professionals managing level measurement assets, understanding VDI 2770 is essential for ensuring that instruments like radar level meters, ultrasonic sensors, and hydrostatic transmitters integrate seamlessly into digital lifecycle management systems.

The Shift to Digital Documentation in Level Measurement

Traditionally, a single level transmitter might be delivered with a thick binder containing operating manuals, safety instructions, calibration certificates, and material declarations. In a large-scale chemical plant with thousands of measurement points, managing these physical documents becomes an administrative bottleneck. VDI 2770 addresses this by standardizing the structure, metadata, and file formats of technical documentation. This allows for the automated exchange of data between manufacturers, plant operators, and maintenance service providers.

By adhering to VDI 2770, manufacturers like Welk ensure that every level measurement device is accompanied by a "digital twin" of its documentation. This digital package is easily searchable, machine-readable, and compatible with Asset Administration Shells (AAS), which are central to the Industry 4.0 framework.

Core Principles of Level Measurement Technologies

Before exploring the documentation requirements of VDI 2770, it is critical to understand the measurement principles of the instruments being documented. Each technology has unique operational parameters that must be accurately reflected in the technical data sheets and manuals.

Radar Level Measurement

Radar level meters utilize Time-of-Flight (ToF) technology. High-frequency microwave pulses (typically 26 GHz or 80 GHz) are emitted by the antenna, reflected off the medium's surface, and received back. The distance is calculated based on the travel time. Because radar is non-contact and unaffected by pressure or temperature fluctuations, the documentation must specify beam angles and dielectric constant (ϵ_r) requirements to ensure accurate setup.

Ultrasonic Level Measurement

Ultrasonic sensors emit sound pressure waves that reflect off the liquid surface. The sensor measures the time interval between emission and reception. Unlike radar, ultrasonic waves are mechanical and require a medium (air) to travel. Therefore, documentation must include temperature compensation data, as the speed of sound varies with air temperature. These sensors are ideal for water treatment but have limitations in vacuum or high-pressure environments.

Hydrostatic Level Measurement

Hydrostatic transmitters measure the pressure exerted by a liquid column at a specific depth. The principle follows the formula $P = \rho \cdot g \cdot h$, where P is pressure, ρ is density, g is gravity, and h is height. Documentation for these devices must clearly state the diaphragm material compatibility and the pressure range to prevent mechanical failure in corrosive chemical applications.

| Key Requirements of VDI 2770

VDI 2770 Part 1 focuses on the "Digital Manufacturer Information." It mandates that all documentation must be provided in a specific container format (usually a ZIP file) containing three primary elements:

1. The Document (PDF/A): All human-readable documents must be in PDF/A format (ISO 19005) to ensure long-term archiving and readability across different software platforms.
2. Metadata (XML): A machine-readable XML file must accompany each document. This file contains standardized metadata such as the document ID, version, language, and the manufacturer's name.

3. The Structure: The documents must be categorized into specific classes, making it easy for plant operators to find the exact information they need during different phases of the plant's life.

Document Classification under VDI 2770

Document Class	Content Type	Examples for Level Meters
Class 1	Technical Documentation	Operating manuals, installation guides, wiring diagrams
Class 2	Administrative Documentation	Order confirmations, packing lists, delivery notes
Class 3	Certificates and Declarations	ATEX/IECEx certificates, Material 3.1 certs, calibration reports

| Evaluation Criteria for Compliance

When evaluating level measurement instruments for a project that requires VDI 2770 compliance, engineers should confirm the following criteria:

Completeness of Metadata: Does the XML file include the mandatory fields defined by the guideline? This includes the "Global Document ID" which prevents duplicates in the operator's system.

Language Localization: VDI 2770 requires that documents be provided in multiple languages if specified by the contract. The XML metadata must correctly tag the language of each PDF/A file.

Classification Accuracy: Are certificates correctly separated from operating manuals? Mixing these in a single PDF file violates the standard and hinders automated processing.

Device Identification: The documentation must be clearly linked to the physical device via a unique identifier, such as a serial number or a Data Matrix code on the instrument's nameplate.

Practical Selection and Implementation

Choosing the right level meter involves balancing the technical measurement requirements with the digital integration needs of the facility. For instance, a magnetic level gauge used in a high-temperature oil refinery requires different documentation (material traceability) compared to an ultrasonic sensor used in a municipal water tank.

Selection Table for Level Measurement Documentation

Application	Recommended Technology	Critical VDI 2770 Documentation
Chemical Storage	80GHz Radar	Ex-protection certificates (Class 3), Chemical resistance charts (Class 1)
Water Treatment	Ultrasonic Sensor	Configuration parameters for foam suppression (Class 1)
Pressurized Tanks	Hydrostatic Transmitter	Pressure test certificates, Diaphragm material specs (Class 3)
High-Level Alarm	Tuning Fork Switch	SIL (Safety Integrity Level) documentation (Class 3)

For a comprehensive overview of available technologies and their specific documentation standards, engineers can Review product options and application support on the Main Page.

Installation and Maintenance Considerations

The implementation of VDI 2770 significantly streamlines the installation and maintenance phases of industrial level meters.

Installation: During the commissioning phase, technicians can scan a QR code on the Welk radar level meter to instantly access the VDI 2770-compliant digital manual on a mobile device. This eliminates the need to carry paper manuals into the field, which can be damaged or lost.

Maintenance: When a level switch requires a periodic proof test, the maintenance management system can automatically pull the relevant calibration and safety certificates from the VDI 2770 package. This ensures that the plant remains in compliance with local safety regulations without manual document retrieval.

Retrofitting: For older plants transitioning to digital management, requesting VDI 2770 compliant data for new replacement parts is the first step toward building a comprehensive digital asset library.

| Common Risks and Limitations

While VDI 2770 offers significant benefits, there are challenges to consider:

1. **Legacy Systems:** Older Document Management Systems (DMS) may not be equipped to parse VDI 2770 XML files. In such cases, the metadata must be entered manually until the software is upgraded.
2. **File Size:** High-resolution PDF/A files for complex instruments can be large. Ensure that the plant's IT infrastructure can handle the storage and transfer of these digital packages.
3. **Supplier Readiness:** Not all manufacturers are fully compliant with VDI 2770. It is crucial to specify compliance in the procurement documents to avoid receiving non-standardized data that requires manual conversion.

| Frequently Asked Questions (FAQs)

Q: Is VDI 2770 mandatory for all industrial equipment?

A: While it is not a legal requirement like the CE marking, it is rapidly becoming a standard contractual requirement in the European process industry and among global chemical and pharmaceutical companies.

Q: How does VDI 2770 relate to the Asset Administration Shell (AAS)?

A: VDI 2770 provides the standardized document content that populates the "Documentation" sub-model of the AAS. It is a foundational component of the digital twin.

Q: Can I convert my existing PDF manuals to VDI 2770?

A: Yes, but it requires more than just saving a file as PDF/A. You must also generate the corresponding XML metadata and package them according to the guideline's structure.

Q: What units should be used in the documentation?

A: Per industrial standards, metric units (e.g., millimeters for level, bar for pressure) are preferred, though imperial units (inches, PSI) may be included for specific regional markets.

| Conclusion

VDI 2770 represents a significant leap forward in the digitalization of the process industry. By standardizing how information for level measurement instruments is delivered and stored, it reduces administrative costs, improves safety, and paves the way for advanced maintenance strategies. Whether you are installing a new radar level meter or upgrading a series of level switches, ensuring that your documentation meets VDI 2770 standards is a critical step in future-proofing your industrial assets. For more technical details on level measurement solutions that meet these modern standards, visit the [Main Page](#).